

# VOC Content Test Certificate

Friday October 19<sup>th</sup>, 2007

Manufacturer: Ardex Australia Pty Ltd (Unit 7, 20 Powers Road, Seven Hills NSW 2147)

Sample Description: Ardex AF142 (fast grab vinyl adhesive)

Date Tested: October 2007 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

|   |                           |
|---|---------------------------|
| <b>Specification</b>  |                           |
| <b>Green Building Council of Australia<br/>Green Star Office Design V2 IEQ-13<br/>Green Star Office Interiors V1.1 IEQ-11</b> | <b>Ardex AF142</b>        |
| Rubber Flooring Adhesive 60 grams per Litre   | <b>38 grams per Litre</b> |
| <b>Specification</b>  |                           |
| <b>Green Building Council of Australia<br/>Green Star Office Design V3 IEQ-13</b>   | <b>Ardex AF142</b>        |
| Rubber Flooring Adhesive 60 grams per Litre   | <b>38 grams per Litre</b> |



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

F0710-15