

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing

A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031

P.O Box 240, North Melbourne, Victoria 3051

Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

Client : Serfloor Australia Pty Ltd
3/237 Princes Highway
Hallam VIC 3803

Test Number : 18-006579
Issue Date : 12/11/2018
Print Date : 12/11/2018

Sample Description SPC - PVC Limestone Composite Vinyl Flooring
End Use : Click lock System
Nominal Composition : PVC & Limestone
Nominal Mass per Unit Area/Density : 10.6kg/m²
Nominal Thickness : 7mm

AS 4586-2013 Appendix A

Slip Resistance Classification of new Pedestrian Surface Materials Wet Pendulum Test Method

Date of Test 12/11/2018
Test Temperature (20±5degC) 24 °C
Sample Preparation Washed with neutral pH detergent and then dried.
Test Direction Length
Fixed/Unfixed Unfixed
Slider No 96 Batch No 77
Length 1 2 3 4 5 SRV
British Pendulum 50 51 48 48 47 49
Number
Classification P4

Equipment: Cooper Pendulum Skid Tester Serial No: 1433-01 Calibrated 16/10/2017
Slider prepared using P400 and 3µm lapping film.

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance and wear on their slip resistance be checked.

147347

32007

Page 1 of 1

© Australian Wool testing Authority Ltd
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing

- Chemical Testing

- Mechanical Testing

- Performance & Approvals Testing

: Accreditation No. 983

: Accreditation No. 985

: Accreditation No. 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



0204/11/06

APPROVED SIGNATORY

MICHAEL A. JACKSON B.Sc. (Hons)
MANAGING DIRECTOR