

## **Slip Check to AS 4586-2013 Loose Lay Vinyl Planks Longboard**

**Report Number: M0966**

**Report Date: 15 September 2020**

**Total Number of Pages 2**

Accredited for compliance with ISO/IEC 17025 – Testing

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

NATA is a signatory to the ILAC Mutual Recognition Arrangement for the mutual recognition of the equivalence of testing, medical testing, calibration and inspection reports


**Issued by**

Safe Environments Pty Ltd  
Unit 4, 40 Bessemer Street  
Blacktown NSW 2148

**Prepared for**

Serfloor Australia Pty Ltd  
1/151-159 Princes Highway  
Hallam VIC 3803

**Approved by**



Dale Rowell  
Authorised Signatory

15 September 2020

# Test Report No. M0966

## Slip Resistance Classification of New Pedestrian Surface Materials

### AS 4586-2013 Appendix D (Oil-Wet Inclining Platform Test)

The slip resistance classification has been determined for unused surfaces using specific conditions. Factors such as usage, cleaning systems, applied coatings and patterns of wear may affect the characteristics of the surface after classification. Standards Australia Handbook 198:2014 *Guide to the specification and testing of slip resistance of pedestrian surfaces* provides guidance for the selection of slip resistant pedestrian surfaces classified in accordance with AS 4586-2013. It is recommended that this test report be read in conjunction with AS 4586 and HB 198.

Requested by: Serfloor Australia Pty Ltd  
Client Address: 1/151-159 Princes Highway  
Hallam VIC 3803

Product Manufacturer: Supplied by Serfloor Australia Pty Ltd  
Product Description: Loose Lay Vinyl Planks Longboard  
Surface Structure: Smooth  
Fixed/Unfixed: Unfixed  
Joint Width: N/A

Test conducted according to: AS 4586-2013 Appendix D (Incorporating Amendment No. 1)  
Location: 4/40 Bessemer Street, Blacktown NSW 2148  
Conducted by: Oshi Barkat & Connor Murphy  
Test Shoe Type: Bergmann with LeipzigV73-SP sole form

Date: 15 September 2020  
Cleaning: As Received  
Air Temperature: 20°C

Displacement Space: Not Measured  
Displacement Space Assessment Group: NA

|   |            |
|---|------------|
| <b>Corrected Mean Overall Acceptance Angle:</b> | <b>11°</b> |
| <b>Slip Resistance Assessment Group:</b>        | <b>R10</b> |

This test report shall not be reproduced unless in full, without written approval of Safe Environments Pty Ltd